

FOCUS Dg



The ceiling will consist of suspended glass fiber ceiling panels Ecophon Focus (edge Dg) conceals the support edges of the tile and creates a distinctive floating appearance in format 600x600x20 mm, 600x1200x20 mm, 1200x1200x25 mm installed with Ecophon Connect grid system: Connect T24 Main runners HD suspended every 1200 mm with Connect Adjustable hanger C1, and Connect T24 Cross tees of 1200 mm and 600 mm length.

The weight of the system (including suspension grid) should be approximately 3-4 kg/m². The visible surface of the ceiling tile will be Akutex™ FT, colour White Frost, painted surface with water-based paint. The edges will be painted. Connect grid system colour should be Connect White 01.

Installation: The system should be installed according to Ecophon installation diagram M202. Edges of cut perimeter tiles should be coated with Connect Edge Sealant. The panels will be easily removable. The minimum height of demountability will be according to the chosen installation method.

Visual appearance: The closest NCS colour of the white visible surface of the panels and the grids will be S 0500-N. The ceiling surface will have a light reflectance of 85% and gloss level below 1.

Acoustic absorption: The ceiling will be of sound absorption class A, will have a weighted sound absorption coefficient α_w of 0,9 and octave band practical sound absorption coefficients (overall depth of system: 200 mm) of:

	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz
20 mm	0.55	0.85	0.85	0.85	1.00	1.00
25 mm	0.50	0.80	0.80	0.90	1.00	1.00

Values will be measured according to EN ISO 354 and classification according to EN ISO 11654.

Articulation Class: At the level of intelligibility, the ceiling will have an articulation class AC (1.5) = 180 according to ASTM E 1111 and E 1110.

Fire safety: The ceiling tiles will be classified A2-s1, d0 according to EN 13501-1; the grid system will be A1. The glass wool core will be tested and classified as non-combustible according to EN ISO 1182.

Mechanical Stability: panels should remain 100% stable in environments reaching up to 95% relative humidity and 30°C temperature. They should be tested according to EN 13964:2014, Annex F.

Indoor Health and Wellbeing: Ceilings panels should comply with the French regulation on VOC emissions, A level. They should also be certified by the Finnish Building Information Group (RTS) with the M1 label. The panels should be free from Substances of Very High Concern (SVHC) above 100 ppm as defined by the European REACH regulation (No 1907/2006).

Circularity: The minimum post-recycled content of ceiling tiles should be 60%. Tiles and grids should be 100% recyclable.

CE marking: The ceiling system should be CE-marked according to the harmonised standard EN 13964:2014 ("Suspended ceilings, requirements and tests methods"), with relevant Declarations of Performance (DoPs) issued.

Maintenance: Daily dusting and vacuum cleaning. Weekly wet wiping.